

□ Orifice

## Sprinkler System Checklist

### **Commercial Buildings**



#### All REFERENCES are to Sections in the 2002 NFPA 13 unless noted otherwise. An asterisk \* indicates a local amendment to the Standards or Codes in adoption during the use of the NOT SHOWN COMPLETED NCORRECT 2002 NFPA 13. **GENERAL** A. Current flow test (within 6 months of 1st submittal) on City of Scottsdale form Fire Hydrant Flow 1. Test Summary (<u>www.cityofscottsdale.gov</u> – search forms) and signed by a qualified Arizona State Registrant (www.btr.state.az.us) or NICET III CET (www.nicet.org) minimum. 14.1.3 (10 & 43), 14.1.4.3 (50)\*, 14.2.1, A.15.2.1. City approved civil plan set (minimum - signed cover sheet and utility sheet) including DR case 2. number. 14.1.4.3 (46)\*. (DR case numbers: search www.scottsdaleaz.gov – My Neighborhood maps, or Case File Search - Planning, Building & Zoning). 3. Manufacturer's data sheets/specification sheets for sprinkler heads pumps, backflow, etc. 14.1.4\*. B. **PLANS** Complete Site Plan, coordinated with Civil/Improvement plans, including locations, sizes and materials of fire lines, exterior hose valves & FDC. 8.16.2.2, 10.1, 14.1.3 (28)(44), 14.1.4.3 (45)\*. 2. Piping plans & full height cross sections of adequate complexity, including: 14.1.3, IBC106.1.1.1. П ☐ Scale ☐ North Arrow □ Dimension ☐ Head Locations ☐ Piping locations, types, sizes & lengths (center to center) ☐ Hangar locations & details ☐ Spare heads & cabinet ☐ Riser location ☐ FDC Connection to system location ☐ Hose valve locations & connection to system locations ☐ Unsprinklered compartments ☐ Location size of concealed spaces Location sizes of closets, pantries, restrooms ☐ Partitions/walls & openings ☐ Elevations/ceiling heights ☐ Slopes ☐ Obstructions ☐ Construction members ☐ Calc areas identified ☐ Calc nodes ☐ Calc areas summaries 3. Sprinkler head legend, per system, including: 6.2.2, 6.2.3, 14.1.3 (12). ☐ SIN ☐ Manufacturer ☐ Type

B. Plans continued

#### Planning & Development Services Department

☐ Quantity

☐ Temperature

7447 E. Indian School Road, Scottsdale, AZ 85251 • Phone: 480-312-7080 • Fax: 480-312-4203



# Sprinkler System Checklist

## **Commercial Buildings**



#### All REFERENCES are to Sections in the 2002 NFPA 13 unless noted otherwise.

An asterisk * indicates a local amendment to the Standards or Codes in adoption during the use of the 2002 NFPA 13.					NOT SHOWN	RECT	COMPLETED	
В.	PLANS continued					S LON	INCORRECT	COMPI
4.	Listing of standard(s), edition, modifications/variances (if applicable) and special design features (include Code or Standard sections as applicable). IFC 102.6, 102.7,104, IBC 101.4, 104, 106.1.1.							
5.	Submittal review: minimum NICET III CET or an Arizona Registrant, evidenced by signature/seal and date. 14.1.4.3 (46)*, IFC 901.2.3.*.							
6.	Names and phone numbers: contractor; NICET/Registrant; whom to call to answer design questions. 14.1.4.3 (48)*.							
7.	Seismic requirements. 9.3*, IBC.							
8.	Occupancy classification/use of each room/area. Ch. 5*, 5.4.3*, A.5 all, 6.2.4, 8.2.4, 8.2.5, 11.214.1.3 (7), Ch. 11, 12 & 13, IFC Ch. 2, IBC Ch. 2.							
9.	Special conditions/occupancy requirement. 8.14, Ch. 11, 12, 13, IFC, IBC.							
10.	Each sprinkler system's allowable square footage. 8.2.1, 8.13.1.							
C.	CALCULATIONS							
1.	Hydraulic calculations, per remote ar	Hydraulic calculations, per remote area, including: Ch. 11, 12, & 13, 14.1, 14.3, 14.4, IFC*.						
	☐ Hazard	☐ Calculation nodes		☐ Area of Application				
	☐ Number of sprinklers calculated	Number of sprinklers calculated						
	☐ Coverage per sprinkler	☐ GPM per sprinkler		(-factor	☐ Orifice size			
	☐ Pipe size, inside	Equivalent pipe lengths						
	☐ Equivalent pipe lengths							
	☐ Friction loss between nodes							
	☐ PSI at each node							
	☐ Total GPM required	GPM required		reams				
	☐ Graph sheet	heet			actor			
	Gridded systems peaked or supplemental calculations							
	☐ Extended coverage or other spec	ial listings limitations						
					C. (	CALCU	LATIONS	S continued

Planning & Development Services Department
7447 E. Indian School Road, Scottsdale, AZ 85251 • Phone: 480-312-7080 • Fax: 480-312-4203



# Sprinkler System Checklist

## **Commercial Buildings**



#### All REFERENCES are to Sections in the 2002 NFPA 13 unless noted otherwise.

An asterisk * indicates a local amendment to the Standards or Codes in adoption during the use of the 2002 NFPA 13.			ECT	TED
C.	CALCULATIONS continued	NOT SHOWN	INCORRECT	COMPLETED
2.	Prior approval for room design method. 11.2.3.3.5*.			
3.	Justification for two sprinklers fed from an existing outlet (separate fire area or calculated). 8.14.19.4.3			
4.	Increased calculation area due to unsprinklered compartments. 8.14.1.2, 11.2.3.1.8.			
5.	Density increases/decreases for slopes/ceiling heights. 11.2.3.2.3, 11.2.3.2.4.			
6.	Standpipe system calculations. NFPA 14, IFC 905.			
7.	Calculations for access challenge hose valves. 8.16.5.2.3*, IFC 905.3.1.1*.			
D.	SPRINKLER SPACING			
1.	Sprinkler head allowable calculated square footage, S x L. 8.5.2, 8.5.2.2, & 8.5.3, listing.			
2.	Allowable calculated spacing to walls, $\frac{1}{2}$ S or L, or small room rule – 9 feet. 8.5.3.2, 8.6.3.2.1, 8.6.3.2.4, listings.			
3.	Minimum sprinkler head spacing. 8.5.3.2.1, listings.			
4.	Sprinkler obstructions and clearances. 8.5.5, 8.5.6, 8.5.7, 8.6 through 8.12, listings.			
5.	Sprinkler head layout for slopes/ 4:12 pitch. 6.2.3, 8.6.4.1.4.4.			
6.	Sidewall sprinklers staggered or outside of spray pattern. 8.7.3.1.6.			
E.	MISCELLANEOUS			
1.	Sprinkler temperature ratings. 8.3.2.			
2.	Quick response sprinkler required. 8.2.5 amended, 8.3.3, IFC 903.3.2, listings.			
3.	Sprinkler coverage at top of elevator shaft (if not current ASTME compliance) and in elevator pit. 8.14.5, 8.14.5.5.			
4.	Sprinkler coverage at top of stairways (noncombustible stairways) and at stairway landings opening to two (2) fire areas. 8.14.3.2.1, 8.14.3.3.			
5.	Sprinkler coverage under the first landing above the bottom of the shaft (noncombustible stairways). 8.14.3.2.1.			
6.	Sprinkler coverage beneath all stairways of combustible construction. 8.14.3.1.			

#### **Planning & Development Services Department**

7447 E. Indian School Road, Scottsdale, AZ 85251 • Phone: 480-312-7080 • Fax: 480-312-4203



# Sprinkler System Checklist



## **Commercial Buildings**

#### All REFERENCES are to Sections in the 2002 NFPA 13 unless noted otherwise.

An asterisk * indicates a local amendment to the Standards or Codes in adoption during the use of the 2002 NFPA 13.		NOT SHOWN	NCORRECT	COMPLETED
E.	MISCELLANEOUS continued	NOT 8	INCOF	COMF
7.	Concealed space coverage except as allowed. 8.14.1, 17.4.4.1.			
8.	Sprinkler heads of a corrosion-resistant type. NOTE: Required where chemicals, moisture or other corrosive vapors can cause corrosion. 6.2.6.1, 6.2.6.4.			
9.	Sprinkler coverage under combustible canopies, canopies used for storage, combustible overhangs over 4 feet, and exterior covered exit ways. 8.14.7*, 8.14.7.2*.			
10.	Sprinkler coverage beneath overhead doors. 8.5.5.3			
11.	Dry pendent sprinkler heads in walk-in coolers/freezers. 8.14.11, 8.15.3.1.1.			
12.	Sprinkler protection for attics in 13-R system. IFC 903.3.1.2.3*.			
13.	Patio and balcony protection in 13R systems. IFC 903.3.1.2.1*.			
F.	PIPING, VALVES, FITTINGS			
1.	Fire sprinkler riser assembly detail per City of Scottsdale detail 2368 or 2369. 8.16.6.6.3*, 15.1.8, IFC 903.3.5 and 903.4.			
2.	Floor control valves. 8.15.1.1.1.1*			
3.	Drain pipes & inspectors tests terminate to the exterior or approved location. 8.15.2.4.4, 8.15.2.6.			
4.	Inspectors test pipe, location and connection to system. 8.16.4.2.1*.			
5.	Exterior exposed piping 2 inch minimum or insulated in an approved manner. 8.15.3.1.3, 8.15.3.1.4*.			
G.	OTHER			
1.	Bell. 6.9.6*, 8.16.1*, IFC 903.4.2*.			
2.	Third party monitoring. IFC 903.4, exception #2*			
3.	The professional registrant in charge or fire code official may require a technical opinion and report, prepared by a qualified party, and/or a professional registrant activities report containing all professional registrant duties as assigned by the State Board of Technical Registration, with seal and signature of an Arizona Registrant, who is qualified in fire sprinkler design, to accompany the plan submittal. IFC 104.7.2, IBC 106.1, 106.3.4.1.			
4.	The professional registrant in charge is responsible to coordinate deferred submittals, professional registrant activities, technical assistance reports, modifications, alternative materials and methods, and to determine that the deferred submittal documents are in general conformance to the design of the building. IFC 104, IBC 104, 106.3.4.			

### **Planning & Development Services Department**

7447 E. Indian School Road, Scottsdale, AZ 85251 • Phone: 480-312-7080 • Fax: 480-312-4203